

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

February 13, 2015

T.S.F. COMPANY, INC. BOB SCHENK 2930 S. ST. PHILLIPS ROAD EVANSVILLE IN 47712

Re: Description: SEWAGE TANKS, RV TRANSFER TANK

Manufacturer: T.S.F. COMPANY, INC.

Product Name: HOLDING TANK

Model Number(s): 440 GAL. Product File No: 20140351

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of February 2020.

This approval supersedes the approval issued on 3/02/10 under product file number 20100109.

This approval is contingent upon compliance with the following stipulation(s):

- This product may only receive waste from recreational vehicles.
- The joints between the tank cover and the inlets and outlet fittings must be made airtight.
- When this tank is installed to receive wastewater from only recreational vehicles, the tank must be installed by either a licensed plumber or a holder of a servicing license issued pursuant to s. 145.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code. All servicing and disposal of the contents from these tanks must be in accord with s. 145.20, Wis. Stats., and ch. NR 113, Wis. Admin. Code.
- This product may only be used as a POWTS holding component in campgrounds permitted by the Department
 of Health Services under ch. DHS 178 or properties where the use of the camping unit transfer container is
 permitted by an adopted governmental unit ordinance and monitored by the governmental unit.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen Jones, M.S. POWTS Product Reviewer phone: (608) 267-5265 fax: (608) 267-9723 email: glen.jones@wi.gov

The DSPS is committed to service excellence. Visit our survey at:

www.surveymonkey.com/s/dspsiscustomersatisfaction

SBD-10564-E (N.10/97) File Ref: 14035101.DOC